

Declaration of Performance No. 0543-CPR-2017-88

Product-type code:	Armaflex Protect
Batch number:	see products label
Intended use:	The pipe penetration seal 'System Armaflex Protect' safeguards the fire resistance in openings in flexible and rigid wall constructions as well as in rigid ceilings which are passed by pipes, accompanying cables and heat tapes.
Manufacturer:	Armacell GmbH Robert-Bosch-Str. 10 D-48153 Münster
System/s of AVCP:	1

The notified body, MPA Braunschweig, NB number 0761, on the basis of ETAG 026-2 and the European Technical Approval (see table) has undertaken the initial type-testing of the construction product, the initial inspection of factory and of factory production control, as well as the continuous surveillance, assessment and evaluation of the factory production control in accordance with System 1 and has issued EC Certificate of Conformity (see table).

European Technical Approval	EC- Certificate of constancy of performance
ETA-11/0454 of 28.02.2017	0761-CPR-0436

Declared performance/s:

Essential characteristics	Performance	Harmonised technical specification
Reaction to Fire	Euroclass E / E _L	EN 13501-1
Resistance to fire	up to EI 120 depending on the execution. Details see ETA-11/0454.	EN 13501-2
Durability and serviceability	Use category Y ₂	ETAG 026-2

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:
Georg Eleftheriadis, Manager Technical Marketing EMEA
Münster, 27.06.2018

[signature]

